

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20192395
Address: 910 NW BLUE PKWY, Unit:P, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Failed	Monday, November 25, 2019

Corrective Action Required:

1	Misc	CHECK ELECTRICAL RECEPTACLES AT DOG WASH ROOM.ENSURE ALL ARE SECURED SOLID.
---	------	---

Corrective Action Required:

2	Misc	MOP SINK MUST BE SEALED TO WALL AND FLOOR.
---	------	--

Corrective Action Required:

3	Misc	LS CODE OF ORDINANCES 17-309: DISPLAY OF "NO SMOKING" SIGN(S) REQUIRED AT PUBLIC ENTRY(IES). SHALL BE CONSPICUOUS AT EACH PUBLIC POINT OF ENTRY.
---	------	--

Comments: