

Inspection Summary

Permit #: PRSUBD20181667, Development - Subdivision
Whispering Woods
Address: 2601 SW PRYOR RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DE - Water Line - Construction Inspection	John DiMauro	Partial	Sunday, November 24, 2019

Informational

1 John DiMauro 11/24/2019 2:31 PM

I met with the Redford crew to flush the water line to prepare for round 2 of water samples on the water line. We will pull a day 1 sample tomorrow.

Comments: