

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20182604
Address: 837 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|------------|----------|----------------------------|
| Rough Framing Inspection - Commercial | John Borns | Partial | Tuesday, November 26, 2019 |

| | |
|---------------------|---|
| Partial Correction: | |
| 1 Misc | OK TO COVER SHEAR WALLS AT ENDS OF BLDG A: NORTH END OF LEFT WING; |
| Partial Correction: | |
| 2 Misc | DECK COLUMNS OK TO COVER AT: RIGHT WING; |
| Partial Correction: | |
| 3 Misc | OK TO COVER WHEN READY FRAMING AT: MAIN FRONT ENTRANCE; TOP OF STAIRWELLS #3 & #4 FOR SCAFFOLDING; |

Comments: