

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20181667
Address: 2601 SW PRYOR RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Water Line - Coliform Test 1	John DiMauro	Failed	Thursday, November 21, 2019

Corrective Action Required:

1	Misc	We collected the day 1 water samples for bacteria testing on Tuesday 11/19/19 and delivered them to Keystone Labs.
		Test spot 2 of the samples failed for total coliforms.
		We will now repeat the sampling process.

Comments: