

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20191389  
Address: 2605 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Brandon Kalwei	Failed	Tuesday, November 26, 2019

Corrective Action Required:

1	Misc	<ul style="list-style-type: none"><li>- fire blocking needed for drop down ceiling NE side in garage</li><li>- loose hold down nuts throughout, still missing washer and nut</li><li>- install nails in double joist hanger at catwalk</li><li>- install solid blocking around and at top plate above fire place, vertical to horizontal, edges needs to be fire foamed ***</li><li>- install solid fire blocking in basement walls, horizontal every 10', and at top plates, edges and penetrations need to be fire foamed</li><li>- ok to insulate</li></ul>
---	------	--

**Comments:**