

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20191166
Address: 150 NW MURRAY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Street - Surface Course	Ronald Paynter	Passed	Tuesday, November 26, 2019

Informational:
1 Misc Hanrahan Asphalt laid 151 tons of APWA Type 3 R asphalt for the surface of the school parking lot. RP 11-26-19

Comments: