



1100 W Cambridge Circle Drive, Suite 700
Kansas City, Kansas 66103
913.627.9040

DAILY FIELD REPORT

CLIENT: Pearl Real Estate Company
919 N East Street
Indianapolis, Indiana 46202

PROJECT: Summit of West Pryor
Apartments
Lee's Summit, Missouri

ATTN: Brad Richey

DATE: 11/8/19

WEATHER: Sunny

CFS
PERSONNEL: M. Simpson

TEMPERATURE: 20-40

REPORT #: 19-1125-dr- 5

TYPE OF SERVICE BEING PERFORMED

SOILS FOUNDATIONS

DEVIATION FOUND: NO

CONCRETE PLACEMENT

DEVIATION CORRECTED:

CONCRETE REINFORCING STEEL

ORIGINAL DEVIATION DATE:

CONCRETE CYLINDER PICK UP

WORK ACCOMPLISHED THIS DATE:

- Inspected footings for 4.0-A to 1.4-A
- All footings met required bearing capacity and size.
- Monitored placement of concrete for Ftgs. 4.0-A to 1.4-A
- One set of 4 test cylinders were cast. Slump and temperature met job requirements.
- Reinforcing steel verified to be in compliance with plans and specifications.
- Cylinder pick up of set 1767.