



1100 W Cambridge Circle Drive, Suite 700  
Kansas City, Kansas 66103  
913.627.9040

## DAILY FIELD REPORT

CLIENT: Pearl Real Estate Company  
919 N East Street  
Indianapolis, Indiana 46202

PROJECT: Summit of West Pryor  
Apartments  
Lee's Summit, Missouri

ATTN: Brad Richey

DATE: 11/15/19

WEATHER: Sunny

CFS  
PERSONNEL: M. Simpson

TEMPERATURE: 24-46

REPORT #: 19-1125-dr- 11

---

### TYPE OF SERVICE BEING PERFORMED

CONCRETE PLACEMENT

**DEVIATION FOUND: NO**

**DEVIATION CORRECTED:**

**ORIGINAL DEVIATION DATE:**

---

### WORK ACCOMPLISHED THIS DATE:

- Monitored placement of concrete for Ftgs.E.5 - 12 to 9.1-J and column ftgs C,D,E,F,G and G.9 on 11 line.
- One set of 4 test cylinders were cast. Slump and temperature met job requirements.
- Reinforcing steel verified to be in compliance with plans and specifications.