



1100 W Cambridge Circle Drive, Suite 700
Kansas City, Kansas 66103
913.627.9040

DAILY FIELD REPORT

CLIENT: Pearl Real Estate Company
919 N East Street
Indianapolis, Indiana 46202

PROJECT: Summit of West Pryor
Apartments
Lee's Summit, Missouri

ATTN: Brad Richey

DATE: 11/18/19

WEATHER: Sunny

CFS
PERSONNEL: M. Simpson

TEMPERATURE: 35-45

REPORT #: 19-1125-dr- 12

TYPE OF SERVICE BEING PERFORMED

SOILS FOUNDATIONS

DEVIATION FOUND: NO

SOILS COMPACTION MONITORING

DEVIATION CORRECTED:

CONCRETE REINFORCING STEEL

ORIGINAL DEVIATION DATE:

WORK ACCOMPLISHED THIS DATE:

- Inspected footings for From 9.1-J to 6.4-J and col. Ftgs. C,D,E,F,G, & G.9 on 10 Line.
- All footings met required bearing capacity and size.
- Observation and monitoring of MODOT type 5 rock placement on interior private road A.
- Inspected reinforcing steel placement for 9.1-J to 6.4-J and col. Ftgs.C,D,E,F,G, AND G.9 on 10 line.
- Reinforcing steel verified to be in compliance with plans and specifications.