



1100 W Cambridge Circle Drive, Suite 700
Kansas City, Kansas 66103
913.627.9040

DAILY FIELD REPORT

CLIENT: Pearl Real Estate Company
919 N East Street
Indianapolis, Indiana 46202

PROJECT: Summit of West Pryor
Apartments
Lee's Summit, Missouri

ATTN: Brad Richey

DATE: 11/19/19

WEATHER: Sunny

CFS
PERSONNEL: M. Simpson / G. Kenyon

TEMPERATURE: 35-55

REPORT #: 19-1125-dr- 13

TYPE OF SERVICE BEING PERFORMED

SOILS FOUNDATIONS

DEVIATION FOUND: NO

CONCRETE PLACEMENT

DEVIATION CORRECTED:

CONCRETE REINFORCING STEEL

ORIGINAL DEVIATION DATE:

OTHER EPOXY INSTALLATION

WORK ACCOMPLISHED THIS DATE:

M. Simpson

- Inspected footings for Footings 9.1 - J to 6.4 - J and Column footings C, D, E, F, G & G.9 on 10 line.
- All footings met required bearing capacity and size.
- Observed drill and epoxy of 22 - #4 dowels at 10./A, 9.4/A, 9.1/A and 5' West, A.5/12.1, B.2/12 AND 8.5/A, with an 8" embedment. No discrepancies noted.

G. Kenyon

- Monitored placement of concrete for Footings 9.1 - J to 6.4 - J and Column footings C, D, E, F, G & G.9 on 10 line.
- One set of 4 test cylinders were cast. Slump and temperature met job requirements.
- Reinforcing steel verified to be in compliance with plans and specifications.