



1100 W Cambridge Circle Drive, Suite 700
Kansas City, Kansas 66103
913.627.9040

DAILY FIELD REPORT

CLIENT: Pearl Real Estate Company
919 N East Street
Indianapolis, Indiana 46202

PROJECT: Summit of West Pryor
Apartments
Lee's Summit, Missouri

ATTN: Brad Richey

DATE: 11/20/19

WEATHER: Sunny

CFS
PERSONNEL: M. Simpson

TEMPERATURE: 40-60

REPORT #: 19-1125-dr- 14

TYPE OF SERVICE BEING PERFORMED

SOILS FOUNDATIONS

DEVIATION FOUND: NO

MASONRY GROUT

DEVIATION CORRECTED:

MASONRY REINFORCING STEEL

ORIGINAL DEVIATION DATE:

WORK ACCOMPLISHED THIS DATE:

- Inspected footings for column footings. C, D, E, F, G & G.9 on 9 line.
- All footings met required bearing capacity and size.
Reinforcing steel found to be in compliance with plans and specifications.
- Monitored placement of grout and inspected reinforcing steel at CMU inspection from B.2 /12 to 9.4-A and A/9.1 to 7.5 ,
from Elev. 88.10 to 92.4 (grouted solid)
- Reinforcing steel verified to be in compliance with plans and specifications.
- Monitored placement of concrete for Column ftgs.C,D,E,F,G,& G.9 ON 9 line.
- One set of 4 test cylinders were cast. Slump and temperature met job requirements.
- Reinforcing steel verified to be in compliance with plans and specifications.