



1100 W Cambridge Circle Drive, Suite 700  
Kansas City, Kansas 66103  
913.627.9040

## DAILY FIELD REPORT

CLIENT: Pearl Real Estate Company  
919 N East Street  
Indianapolis, Indiana 46202

PROJECT: Summit of West Pryor  
Apartments  
Lee's Summit, Missouri

ATTN: Brad Richey

DATE: 11/21/19

WEATHER: Overcast

CFS  
PERSONNEL: M. Simpson

TEMPERATURE: 40-50

REPORT #: 19-1125-dr- 15

---

### TYPE OF SERVICE BEING PERFORMED

**SOILS** FOUNDATIONS

**DEVIATION FOUND: NO**

**MASONRY** GROUT

**DEVIATION CORRECTED:**

**MASONRY** REINFORCING STEEL

**ORIGINAL DEVIATION DATE:**

**CONCRETE** CYLINDER PICK UP

---

### WORK ACCOMPLISHED THIS DATE:

- Inspected footings for Column footings 7.9/C-D-E-G & G.9 and 7/C--D-E-F-G & G.9
- All footings met required bearing capacity and size.
- Reinforcing steel found to be in compliance with plans and specifications.
- Monitored placement of grout and inspected reinforcing steel at A/8.7 -10.2 from elevation 88.10 to 92.4 & A/12 to 11.2 from Elevation 88.10 to 92.4 All wall sections grouted solid.
- Reinforcing steel verified to be in compliance with plans and specifications.
- Cylinder pick up of set 1878.