

1100 W Cambridge Circle Drive, Suite 700 Kansas City, Kansas 66103 913.627.9040

DAILY FIELD REPORT

CLIENT: Pearl Real Estate Company PROJECT: Summit of West Pryor

919 N East Street Apartments

Indianapolis, Indiana 46202 Lee's Summit, Missouri

ATTN: Brad Richey DATE: 11/25/19

CFS

WEATHER: Overcast PERSONNEL: M. Simpson / G. Kenyon

TEMPERATURE: 40-60 REPORT #: 19-1125-dr- 17

TYPE OF SERVICE BEING PERFORMED

SOILS FOUNDATIONS DEVIATION FOUND: NO

CONCRETE CYLINDER PICK UP DEVIATION CORRECTED:

ORIGINAL DEVIATION DATE:

WORK ACCOMPLISHED THIS DATE:

M. Simpson

- · Inspected footings for column footings at 5.9/C D E F G and G .9 and 5.2/C D E F G and G .9
- · All footings met required bearing capacity and size.

G. Kenyon

· Cylinder pick up of set 1901.