

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20183200  
Address: 1706 NW OBRIEN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	John Borns	Passed	Wednesday, November 27, 2019

**Comments: COMPONENTS OF RATED WALL AND CEILING ASSEMBLY AT EAST CONNECTING CORRIDOR: AT WALL ABOVE CEILING 5/8" GWB OVER 1" LINER BOARD; GWB CEILING.**