

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816) 969-1200 FAX (816) 969-1201

# Temporary Certificate of Occupancy

---

Permit #: PRRES20190941  
Address: 4520 SW NAUTILUS PL, LEES SUMMIT, MO 64082  
Inspected On: Wednesday, November 27, 2019  
Inspected By: Brandon Kalwei  
Expiration Date: 11/27/2019 12:00:00 AM

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Brandon Kalwei	Temporary C of O	Wednesday, November 27, 2019

Corrective Action Required:

1	Misc	** All water is to be discharge 3' from foundation, sump pump discharge ** splash blocks needed ** grading at north and west side needs to be fixed, grading cannot be within 6" of siding
---	------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------