

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary

Certificate of Occupancy

Permit #: **PRRES20190941**
Address: **4520 SW NAUTILUS PL, LEES SUMMIT, MO 64082**
Inspected On: **Wednesday, November 27, 2019**
Inspected By: **Brandon Kalwei**
Expiration Date: **11/27/2019 12:00:00 AM**

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Brandon Kalwei	Temporary C of O	Wednesday, November 27, 2019

Corrective Action Required:

1	Misc	** All water is to be discharge 3' from foundation, sump pump discharge ** splash blocks needed ** grading at north and west side needs to be fixed, grading cannot be within 6" of siding
---	------	--