

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20182733  
Address: 2528 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Gas Service Inspection - Residential</b>	Brandon Kalwei	Failed	Wednesday, November 27, 2019

Corrective Action Required:

1	Misc	Need minimum of 15lbs of pressure to perform inspection
---	------	---

No erosion control at front and rear of lot, needs to be installed before next inspection. Lot is at rough grade stage.

**Comments:**