

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20192844

Address: 2931 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Water Line - Construction Inspection</b>	John Jackson	Partial	Wednesday, November 27, 2019

Informational:

1

6" C-900 water Line A was completely installed, next week testing of Line will begin. Thurst blocks were poured behind bends & tees and bolts for Mega lugs & restraints were sprayed with black epoxy. 11/27/19

**Comments:**