

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192141
Address: 4410 SW AMETHYST DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Brandon Kalwei	Failed	Monday, December 02, 2019

Corrective Action Required:

1	Misc	-Garage attic access clearance needs to be code compliant, less than 30" front top of framing to bottom of framing, new location is measuring at 24" - properly fireblock double wall top plates in basement - fire block electrical penetrations through top floor above north basement bedroom egress window - over bored studs in downstairs bathroom
---	------	---

Do not insulate

Comments: