

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191953
Address: 1708 NW CHIPMAN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Failed	Monday, December 02, 2019

Corrective Action Required:

- | | | |
|----|---|---|
| 1 | Misc | EXHAUST AIR CONTRACTOR NO SHOW FOR FINAL INSPECTION. 25 CFM EXHAUST AIR REQUIRED LOCAL AT POINT OF WORK AT EVERY STATION. |
| 2. | FLUSH HANDLE MUST BE ON FREE SIDE OF TANK IN ACCESSIBLE RESTROOM. | |

Comments: