



1100 W Cambridge Circle Drive, Suite 700
Kansas City, Kansas 66103
913.627.9040

DAILY FIELD REPORT

CLIENT: Pearl Real Estate Company
919 N East Street
Indianapolis, Indiana 46202

PROJECT: Summit of West Pryor
Apartments
Lee's Summit, Missouri

ATTN: Brad Richey

DATE: 11/26/19

WEATHER: Overcast

CFS
PERSONNEL: M. Simpson

TEMPERATURE: 40-62

REPORT #: 19-1125-dr- 18

TYPE OF SERVICE BEING PERFORMED

MASONRY GROUT

DEVIATION FOUND: NO

MASONRY REINFORCING STEEL

DEVIATION CORRECTED:

CONCRETE PLACEMENT

ORIGINAL DEVIATION DATE:

WORK ACCOMPLISHED THIS DATE:

- Monitored placement of grout and inspected reinforcing steel at A-line/9.6 to 10.4, elevation 92.4 to 96.4 and from A-line/10.4 to 13.4, elevation 96.4 to 100.4 (walls are solid grout)
- Reinforcing steel verified to be in compliance with plans and specifications.
- Monitored placement of concrete for Column footings at 5.9/C- D - E - F - G and G.9, 5.0/C- D - E - F - G and G.9, step footing at 7.9 - G and elevator pit walls at 7.4 - A. 5
- One set of 4 test cylinders were cast. Slump and temperature met job requirements.
- Reinforcing steel verified to be in compliance with plans and specifications.