



1100 W Cambridge Circle Drive, Suite 700
Kansas City, Kansas 66103
913.627.9040

DAILY FIELD REPORT

CLIENT: Pearl Real Estate Company
919 N East Street
Indianapolis, Indiana 46202

PROJECT: Summit of West Pryor
Apartments
Lee's Summit, Missouri

ATTN: Brad Richey

DATE: 11/27/19

WEATHER: Overcast

CFS
PERSONNEL: M. Simpson

TEMPERATURE: 33-44

REPORT #: 19-1125-dr- 19

TYPE OF SERVICE BEING PERFORMED

MASONRY GROUT

DEVIATION FOUND: NO

MASONRY REINFORCING STEEL

DEVIATION CORRECTED:

CONCRETE PLACEMENT

ORIGINAL DEVIATION DATE:

CONCRETE REINFORCING STEEL

WORK ACCOMPLISHED THIS DATE:

- Monitored placement of grout and inspected reinforcing steel at A line/ 3.9 to 4.6, elevation 88.0 to 92.0 AFF, A line/ 9.4 to 10.6, elevation 96.0 to 100.4 AFF. Walls grouted solid.
- Reinforcing steel verified to be in compliance with plans and specifications.
- Monitored placement of concrete for Elevator pit footing at F. 5 on G line and column footing at G. 9 - 5
- One set of 4 test cylinders were cast. Slump and temperature met job requirements.
- Reinforcing steel verified to be in compliance with plans and specifications.