

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20191389
Address: 2605 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Brandon Kalwei	Not Ready	Tuesday, December 03, 2019

Corrective Action Required:

1 Misc

- loose hold down nuts throughout, still missing washer and nut NE wall
- install nails in double joist hanger at catwalk

Not ready inspection fee has been issued for the remaining items, needs to be paid before next inspection

- ok to insulate

Comments: