CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #:PRSUBD20191897Address:3200 SW PERGOLA PARK DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:	
DE - Street - Proof	Roll Ronald Paynter	Failed	Tuesday, December 03, 2019	
Informational:				
1 Misc	sections on 3 differen	Had a tandem dump truck with a 20.81 ton load. Had pumping in 3 different sections on 3 different roads. Will check with Steve Robbins to see in we can redo the proof roll with the asphalt truck. RP 12-3-19		

Comments: