

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20191389  
Address: 2605 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Brandon Kalwei	Failed	Tuesday, December 03, 2019

Corrective Action Required:

1 Misc

- loose hold down nuts throughout, still missing washer and nut NE wall
- install nails in double joist hanger at catwalk

Not ready inspection fee has been issued for the remaining items, needs to be paid before next inspection

- ok to insulate

**Comments:**