

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816) 969-1200 FAX (816) 969-1201

# Temporary Certificate of Occupancy

---

Permit #: PRCOM20191953  
Address: 1708 NW CHIPMAN RD, LEES SUMMIT, MO 64081  
Inspected On: Wednesday, December 04, 2019  
Inspected By: Mark Harding  
Expiration Date: 12/20/2019 12:00:00 AM

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Mark Harding	Temporary C of O	Wednesday, December 04, 2019

Corrective Action Required:

2	Misc	ICC A117.1 SECTION 604.6: ACCESSIBLE WATER CLOSET FLUSH VALVE HANDLE MUST BE AT FREE SIDE OF TANK. Tank on order and will be in 12/9-12/19 TCO good to 12/20
---	------	--