

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20191957  
Address: 930 NW BLUE PKWY, Unit:E, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Mark Harding	Partial	Wednesday, December 04, 2019

Corrective Action Required:  
9 Misc Rear wall at firewall to corridor. Hole in firewall above wall switch above ceiling. Contractor to leave ceiling visible for reinspection.

**Comments:**