

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20172515  
Address: 225 NW KESSLER DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Mark Harding	Partial	Wednesday, December 04, 2019

Corrective Action Required:

1	LOWER LEVEL	ok
---	-------------	----

Corrective Action Required:

2	SECOND FLOOR	RC OK
---	--------------	-------

Screw pattern needs corrected and holes in ceiling in units repair corridor wall gaps.

Corrective Action Required:

3	FIRST FLOOR	
---	-------------	--

RC OK  
units ok repair corridor wall gaps.

Corrective Action Required:

4	THE FOLLOWING AREAS ARE APPROVED	OK TO SET TUBS ONLY PRE-ROCK OK Units ok to cover-
---	----------------------------------	--

**Comments:**