

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRCOM20172503
Address: 205 NW KESSLER DR, LEES SUMMIT, MO 64081
Inspected On: Wednesday, December 04, 2019
Inspected By: Mark Harding
Expiration Date: 12/27/2019 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Mark Harding	Temporary C of O	Wednesday, December 04, 2019

Corrective Action Required:

1 Misc Approved for TCO pending the the following items are corrected and inspected when completed.

Correct Electrical issue in unit 204 for Water heater disconnect. GFCI tripping at bathroom.
addressed on site.
- seal all exterior light penetrations.
--label all AC disconnects and secure whips within 12 " of box.
-- install anti-siphon on hose bib Fire sprinkler room.
--Fire caulk ceiling of sprinkler room.
-- Label main MDP
--Handrails on garage 6-12

