

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20192706  
Address: 940 NW PRYOR RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Concrete Walls and Columns Inspection</b>	John Borns	Partial	Thursday, December 05, 2019

Partial Correction:

1 Misc

OK TO POUR WHEN READY C.I.P. WALL AT:  
**12/H.5 TO I/12 TO I/10;**

ENSURE KEYWAY AND WATERSTOP ARE CLEAR AND CLEAN PRIOR TO  
BUTTONING-UP FORMS.

**Comments:**