

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20183155
Address: 3329 SW JESSIE CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Brandon Kalwei	Failed	Thursday, December 05, 2019

Corrective Action Required:

1	Misc	- garage entrance door needs to be self closing and latching, needs to be self latching - deck stairs need to have code compliant handrail, not fully graspable the whole distance - Gfci in front bathroom not working properly - sheet rock needs to be installed under stair stringers in unfinished basement area - final grade, sod - as graded plot plan needs to be submitted, reviewed and approved by front counter staff
---	------	--

Comments: