## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 DEVSERVICES.CITYOFLS.NET

## **Inspection Summary**

Permit #: PRCOM20182604 Address: 837 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:	
Rated Assembly Inspection	John Borns	Partial	Thursday, December 05, 2019	
Partial Correction:				
1 Misc	OK TO COVER WHEN READY 5/8" MOLD-RESISTANT FIRECODE X GWB AT STAIRWELL WALLS INSIDE FACE AND SPACES BETWEEN JOISTS AT BACKSIDE:			
	STAIRWELL 1: 1ST FLOOR: 1ST LAY 2ND FLOOR: 1ST LAY 3RD FLOOR: 1ST LAY 4TH FLOOR:	(ER; 2ND LAYER;		
	STAIRWELL 2:			
	1ST FLOOR: 1ST LAYER; 2ND LAYER; 2ND FLOOR: 1ST LAYER; 2ND LAYER @ 2 OF 3 WALLS; 3RD FLOOR: 1ST LAYER; 2ND LAYER; 4TH FLOOR:			
	STAIRWELL 3: 1ST FLOOR: 1ST LAY 2ND FLOOR: 1ST LAY 3RD FLOOR: 1ST LAY 4TH FLOOR: 1ST LAY	(ER; 2ND LAYER;	ILY;	

	STAIRWELL 4: 1ST FLOOR: 1ST LAYER; 2ND LAYER; 2ND FLOOR: 1ST LAYER; 2ND LAYER; 3RD FLOOR: 1ST LAYER; 2ND LAYER; 4TH FLOOR: 1ST LAYER; 2ND LAYER INSIDE ONLY;
	NOTE: FIRESTOPPING WHERE PVC PIPE INTERRUPTS GWB IS SUBJECT TO APPROVAL WHEN COMPLETED. USE ONLY LISTED FIRECAULK;
Partial Correction: 2 Misc Partial Correction: 3 Misc	OK TO COVER WHEN READY 5/8" MOLD-RESISTANT FIRECODE X GWB @ ELEVATOR SHAFTS:
	ELEVATOR #1: SPACES BETWEEN JOISTS AT BACKSIDE 1ST FLOOR: 1ST & 2ND LAYERS WALL INTERIOR FACE: FULL HEIGHT 1ST LAYER CEILING: 1ST LAYER
	ELEVATOR #2: SPACES BETWEEN JOISTS AT BACKSIDE 1ST FLOOR: 1ST & 2ND LAYERS
	WALL INTERIOR FACE: FULL HEIGHT 1ST LAYER; 2ND LAYER
	CEILING: 1ST LAYER; 2ND LAYER; 3RD LAYER + HAT CHANNEL;
	OK TO COVER WHEN READY 5/8" MOLD-RESISTANT FIRECODE X GWB @ DATA/ELECT RMS AT:
	1ST FLOOR RIGHT WING: EAST DATA: 1 LAYER; 2 LAYERS @ CORR WALL; WEST DATA: 1 LAYER; 2 LAYERS @ CORR WALL;
Partial Correction: 4 Misc	1ST FLOOR LEFT WING: DATA/ELECT: 1 LAYER; 2 LAYERS @ CORR WALL; MECH RM: 2 LAYERS @ CORR WALL
	OK TO COVER WHEN READY 5/8" TYPE X GWB AT:
	A.AA FROM A.5 TO A.6 FROM 1ST FLOOR TO 3RD FLOOR ABOVE FIREPLACE 2 LAYERS; FIREWALL AT LEFT WING 1ST AND 2ND LAYERS;

Comments: