

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20191320
Address: 1805 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Brandon Kalwei	Failed	Friday, December 06, 2019

Corrective Action Required:

1	Misc	-As graded plot plan needs to be submitted and reviewed by front counter staff -ledger locks needed at rear deck -Guard rail needed on west side of front porch
---	------	---

Comments: