

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20191391  
Address: 1837 SW BLACKSTONE CT, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                | Inspector:   | Outcome: | Date:                     |
|----------------------------|--------------|----------|---------------------------|
| <b>Driveway Inspection</b> | John DiMauro | Failed   | Monday, December 09, 2019 |

Informational:  
1        Misc        PRE POUR INSPECTION

The forms are set and there appears to be sufficient compacted aggregate.

Corrective Action Required:  
2        Misc        POST POUR INSPECTION FAILED.

The driveway approach cross slope is greater than 2.0 % and is not in ADA compliance.

Corrections to the driveway approach will need to be made prior to issuance of a Certificate of Occupancy.

**Comments:**