

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20182611  
Address: 901 NW WARD RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	John Borns	Partial	Tuesday, December 10, 2019

Partial Correction:

1	Misc	OK TO COVER WHEN READY 5/8" MOLD-RESISTANT FIRECODE X GWB AT STAIRWELLS INSIDE FACE & SPACES BETWEEN JOISTS AT BACKSIDE:
---	------	--

EAST STAIRWELL #1:  
BASEMENT LEVEL: 1ST LAYER; 2ND LAYER  
1ST FLOOR: 1ST LAYER; **2ND LAYER**  
2ND FLOOR:  
3RD FLOOR:  
4TH FLOOR:

WEST STAIRWELL #2:  
BASEMENT LEVEL: 2 LAYERS  
1ST FLOOR: 1ST LAYER; **2ND LAYER**  
2ND FLOOR:  
3RD FLOOR:  
4TH FLOOR:

Partial Correction:

2	Misc	OK TO COVER WHEN READY 5/8" MOLD-RESISTANT FIRECODE X GWB AT ELEVATOR SHAFT:
---	------	--

BACKSIDE BETWEEN TRUSS JOISTS:

BASEMENT LEVEL: 2 LAYERS

1ST FLOOR: 1ST LAYER; **2ND LAYER**

2ND FLOOR:

3RD FLOOR:

4TH FLOOR:

**Comments:**