CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #:PRCOM20190274Address:2861 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspect	ion:	Inspector:	Outcome:	Date:	
Rated Assembly Inspection		Khanh Nguyen	Partial	Wednesday, December 11, 2019	
Correcti	ive Action Required:				
1	Misc	sc 2-HR FIRE BARRIER WALL:			
			ST FL WALL FROM H.8/7 TO J.5/7-1ST LAYER ON BOTH SIDES OK. NORTH SIDE		
		2ND LAYER OK.			
		-WALL IN ELECTRICAL	RM-2ND LAYER OK		
		ELEVATOR SHAFT WAI	EVATOR SHAFT WALL: 1" GYP BOARD INSTALLATION-OK; OUTER LAYER IN		
		PROGRESS; ELEVATOR	ROGRESS; ELEVATOR EQUIPMENT RM WALL IN PROGRESS		

Comments: