

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191907
Address: 1901 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|------------|----------|---------------------------------|
| Underground Electrical Inspection - Commercial | John Borns | Partial | Wednesday, December 11, 2019 |

Partial Correction:

| | | |
|---|------|---|
| 1 | Misc | THREE LIGHT POLE BASES APPROVED FOR POUR -- ONE ADDITIONAL AND TWO REPLACEMENTS -- FOR TOTAL OF SEVEN. OK TO POUR WHEN READY. |
|---|------|---|

Partial Correction:

| | | |
|---|------|--|
| 2 | Misc | TRENCHED CONDUIT OK TO COVER: ONE 2" SECONDARY FROM BUILDING TO 25' EAST ONE 1-1/2" FROM BUILDING TO 30' NORTH FOR SITE LIGHTING FEED. |
|---|------|--|

Comments: