

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20172502
Address: 201 NW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pool Steel/Bonding - Commercial	Khanh Nguyen	Failed	Wednesday, December 11, 2019

Corrective Action Required:

1	Misc	Pool base, ladders, and lights
---	------	--------------------------------

****PARTIAL AREA BETWEEN STAIR:**

-INSTALL A LISTED BONDING CLAMP THAT MAKE A TIGHT CONNECTION TO REINFORCING STEEL

-PERIMETER BONDING REQUIRES MIN 4 BONDING JUMPERS EQUALLY SPACED AROUND THE POOL

Comments: