

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20192650

Address: 855 NE WOODS CHAPEL RD, Unit:IR, LEES SUMMIT, MO 64064855 NE WOODS CHAPEL RD, LEES SUMMIT, MO 64064851 NE WOODS CHAPEL RD, Unit:IR, LEES SUMMIT, MO 64064851 NE WOODS CHAPEL RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Curb - Proof Roll	John Jackson	Partial	Tuesday, December 10, 2019

Corrective Action Required:

1 No proof roll was done for Taco Bell Drive-Thru. Contractor was informed of the oversight. Inspector will continue to monitor site to ensure visaul curb quality.

Informational:

2 Misc Proof of subgrade passed for curbs and dumpster landing pad.

Informational:

3 Misc Proof Rolled of parking lot passed 12/11/19 5:00pm.

Comments: