

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20182604
Address: 837 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Wednesday, December 11, 2019

Partial Correction:

1 Misc

OK TO COVER WHEN READY 5/8" MOLD-RESISTANT FIRECODE X GWB AT STAIRWELL WALLS INSIDE FACE AND SPACES BETWEEN JOISTS AT BACKSIDE:

STAIRWELL 1:

1ST FLOOR: 1ST LAYER; 2ND LAYER;
2ND FLOOR: 1ST LAYER; 2ND LAYER;
3RD FLOOR: 1ST LAYER; 2ND LAYER;
4TH FLOOR:

STAIRWELL 2:

1ST FLOOR: 1ST LAYER; 2ND LAYER;
2ND FLOOR: 1ST LAYER; 2ND LAYER @ 2 OF 3 WALLS;
3RD FLOOR: 1ST LAYER; 2ND LAYER;
4TH FLOOR:

STAIRWELL 3:

1ST FLOOR: 1ST LAYER; 2ND LAYER;
2ND FLOOR: 1ST LAYER; 2ND LAYER;
3RD FLOOR: 1ST LAYER; 2ND LAYER;
4TH FLOOR: 1ST LAYER; 2ND LAYER INSIDE ONLY;
TOP OF TOWER: 1ST & 2ND LAYERS ABOVE CLG @ W WALL; CEILING AND

WALLS BELOW CEILING 1ST & 2ND LAYERS;

STAIRWELL 4:

1ST FLOOR: 1ST LAYER; 2ND LAYER;

2ND FLOOR: 1ST LAYER; 2ND LAYER;

3RD FLOOR: 1ST LAYER; 2ND LAYER; 2ND LAYER AT BACKSIDE @ UNITS & CORRIDOR

4TH FLOOR: 1ST & 2ND LAYERS INSIDE FACE ONLY; 1ST LAYER AT BACKSIDE; 2ND LAYER AT BACKSIDE

TOP OF TOWER: 1ST LAYER; 2ND LAYER AT WALLS & AT UPPER & LOWER CEILINGS; 3RD LAYER + HAT CHANNEL;

NOTE: FIRESTOPPING WHERE PVC PIPE INTERRUPTS GWB IS SUBJECT TO APPROVAL WHEN COMPLETED. USE ONLY LISTED FIRECAULK;

Partial Correction:

2 Misc

OK TO COVER WHEN READY 5/8" MOLD-RESISTANT FIRECODE X GWB @ ELEVATOR SHAFTS:

ELEVATOR #1:

SPACES BETWEEN JOISTS AT BACKSIDE

:

1ST FLOOR: 1ST & 2ND LAYERS

WALL INTERIOR FACE: FULL HEIGHT 1ST LAYER

CEILING: 1ST LAYER

ELEVATOR #2:

SPACES BETWEEN JOISTS AT BACKSIDE

:

1ST FLOOR: 1ST & 2ND LAYERS

EXTERIOR FACE: 4TH FLOOR 1ST LAYER + 2ND LAYER; 3RD FLOOR 1ST LAYER;

WALL INTERIOR FACE: FULL HEIGHT 1ST LAYER; 2ND LAYER

CEILING: 1ST LAYER; 2ND LAYER; 3RD LAYER + HAT CHANNEL; 4TH LAYER

Partial Correction:

3 Misc

OK TO COVER WHEN READY 5/8" MOLD-RESISTANT FIRECODE X GWB @ DATA/ELECT RMS AT:

1ST FLOOR RIGHT WING:

EAST DATA: 1 LAYER; 2 LAYERS @ CORR WALL;

WEST DATA: 1 LAYER; 2 LAYERS @ CORR WALL;

1ST FLOOR LEFT WING:

DATA/ELECT: 1 LAYER; 2 LAYERS @ CORR WALL;

MECH RM: 2 LAYERS @ CORR WALL

Partial Correction:

4

Misc

OK TO COVER WHEN READY 5/8" TYPE X GWB AT FIREWALL:

LEFT WING:

4TH FLOOR:

WEST FACE: 1ST AND 2ND LAYERS ABOVE CEILING; BELOW CEILING 1ST AND 2ND LAYERS;

EAST FACE: 1ST LAYER ABOVE CEILING;

3RD FLOOR:

WEST FACE:

BELOW CEILING: 1ST LAYER;

Comments: