

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20193595
Address: 920 NE DEERBROOK ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Electrical Inspection - Commercial	Khanh Nguyen	Failed	Thursday, December 12, 2019

Corrective Action Required:

1	Misc	-CONNECT THE GROUNDING ELECTRODE CONDUCTOR TO THE GROUDED BUS BAR WHERE THE SERVICE GROUNDED CONDUCTOR IS CONNECTED TO (250.24) -BONDING CONNECTION REQUIRES MIN 2 THREADS OF METAL-METAL CONTACT OR REMOVE ENAMEL (250.118)
---	------	---

Comments: