

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20172502  
Address: 201 NW KESSLER DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Pool Steel/Bonding - Commercial</b>	Khanh Nguyen	Partial	Thursday, December 12, 2019

Corrective Action Required:

1	Misc	Pool base, ladders, and lights
---	------	--------------------------------

**\*\*AREA ADJACENT TO THE ROUND POOL BETWEEN STAIRS\*\***  
BONDED COMPONENTS: LADDER, HANDICAP POLE, PERIMETER SURFACE  
REINFORCEMENT STEEL, BONDING CONNECTION TO POOL SHELL REBAR

**Comments:**