

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20191897
Address: 3200 SW PERGOLA PARK DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Street - Base Lift	Ronald Paynter	Passed	Thursday, December 12, 2019

Informational:
1 Misc Contractor was able to successfully complete (Asphalt base) for Pergola 4th Plat except for a 25' long patch on SW Redbuck Cir. That runs curb to curb. The bas asphalt that was used is APWATYPIAWA TYP 5 RECYCLE. Please see picture of fail proof roll for 12/7/19.

Informational:
2 Misc John's crew from Hanrahan Asphalt step cut the existing base to adhere the unfinished base section. They used APWA type 5 recycled asphalt for this section. RP 12-12-19

Comments: