

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20191957  
Address: 930 NW BLUE PKWY, Unit:E, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	John Borns	Failed	Friday, December 13, 2019

Corrective Action Required:

1	Misc	NEC 600.3 UL LISTING OF EXTERIOR LIGHTED SIGNS / DECORATIVE ELEMENTS: IF INTERNALLY LIGHTED, MUST BE UL SHOP-LABELED AS INDICATION OF LISTING.
---	------	--

Corrective Action Required:

2	Misc	NEC 408.4 ELECTRICAL PANEL SCHEDULES: ENSURE ALL CIRCUIT POSITIONS ARE PROPERLY LABELED. MUST BE LEGIBLE, COMPLETE, CURRENT, SPECIFIC. NO DITTO MARKS OR CONTINUATION SYMBOLS EXCEPT @ MULTIPLE POLE BREAKERS. LABEL UNUSED BREAKERS "SPARE".
---	------	---

Corrective Action Required:

3	Misc	SOME DEVICES NOT INSTALLED OR NOT HOT FOR TEST. EXAMPLES: EXAM 1 E WALL; EXAM 4 E WALL;
---	------	---

Corrective Action Required:

4	Misc	NO LIGHTING AT OFFICE
---	------	-----------------------

Corrective Action Required:

5	Misc	GLASS DOORS NOT HUNG
---	------	----------------------

Corrective Action Required:

6	Misc	CORRECT FIRE DEPT ISSUES
---	------	--------------------------

Partial Correction:

7	Misc	OCCUPANCY STATUS: OK TO SET UP FOR BUSINESS. STAFFING, TRAINING, FIXTURING, STOCKING OK. NO PUBLIC/CUSTOMERS/PATIENTS PRIOR TO APPROVAL.
---	------	--

**Comments:**