

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20191770

Address: 2861 NE INDEPENDENCE AVE, Unit:101, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	Khanh Nguyen	Partial	Friday, December 13, 2019

Partial Correction:

1 Misc

IN-WALL INSPECTED:

-1100, 1100.1-.2, 1101-1105, 1134, 1150-1152

**\*\*INSTALL PROTECTIVE PLATE FOR PVC PLUMBING LOCATED WITHIN 1.25" OF BOTTOM PLATE**

**Comments:**