

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20191159  
Address: 120 SW BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Pool Steel/Bonding - Commercial</b>	John Borns	Partial	Monday, December 16, 2019

Partial Correction:

1 Misc

NO ISSUES FOUND ON EQUIPOTENTIAL BONDING AT:  
POOL BOTTOM SLAB - LEADS STUBBED UP ABOVE POUR LINE; **WEST POOL WALL FROM NORTH ALONG WIDTH OF SURGE TANK; EAST POOL WALL NORTH 25'**;

**Comments:**