

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191809
Address: 851 NE WOODS CHAPEL RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Hood/Duct Inspection	Khanh Nguyen	Failed	Monday, December 16, 2019

Corrective Action Required:

1	Misc	-RE-WELD THE CUT-OUT SECTION **CLEAN OUT MUST MEET IMC 506.3.8. HAVE ENGINEER OK THIS IF YOU STILL WANT A CLEANOUT THERE, BYUT THE CLEANOUT MUST STILL MEET 506.3.8 WITH NO SCREWS PENETRATING THE DUCT
---	------	--

Comments: