CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20170401

Address: 3530 SW HOLLYWOOD DR, Unit:3, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Brandon Kalwei Failed Monday, December

Commercial 16, 2019

Corrective Action Required:

1 Misc 307- missing cover plates and spark rings, 1 upper. Lockout for water heater

that is hardwired. Label panel. 305-Lockout on water heater.

209- missing uppers and backsplash cover plates .

206-missing uppers no backsplash, outlets & cover plates not set.

207-same as 206.

106-uppers same as 206,207.

108- lowers & uppers anti tip device on stove, kit counter outlets.

Storage

>>Center IT Room install metal sleeves to ceiling and secure on all low

voltage and cables.

>> Basement north end—ok

06- anti tip stove outlets and 1 upper. Electrical panel not Labeled.

08-no kitchen uppers & lower counters, electrical or plumb, sink, etc. No

inspection of Kitchen

Install Lockouts on all hardwired appliances not within sight of panel. Install all ranges and anti-tip devices. Complete all unfinished counter, uppers,

lowers, back splash, spark rings on outlets & covers.

Need to inspect roof top

Comments:	
------------------	--