

ANALYTICAL REPORT

December 16, 2019

Work Order: 1L91040

Page 1 of 3

Report To
Joe Starlin City of Lee's Summit - Public Works Dept. 220 SE Green Str Lees Summit, MO 64063

Work Order Information
Date Received: 12/12/2019 2:16PM Collector: Client Phone: (816) 969-7428 PO Number: Routine Analysis

Project : Emery Sapp & Sons

Project Number: SWP

Analyte	Result	MRL	Batch	Method	Analyst	Analyzed	Qualifier
1L91040-01	E			Matrix:Drink Wtr		Collected: 12/12/19 13:35	
Total Coliforms	<1.0 MPN/100ml	1.0	1CL0533	9223B-QT	CLJ	12/12/19 15:30	
E. Coli	<1.0 MPN/100ml	1.0	1CL0533	9223B-QT	CLJ	12/12/19 15:30	

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Samples were preserved in accordance with 40 CFR for pH adjustment unless otherwise noted. MRL= Method Reporting Limit.

City of Lee's Summit - Public Works Dept.
220 SE Green Str
Lees Summit, MO 64063

December 16, 2019

Page 2 of 3

Work Order: 1L91040

Certified Analyses included in this Report

Method/Matrix	Analyte	Certifications
9223B-QT in Drink Wtr		
	Total Coliforms	KS-KC,MO-KC
	E. Coli	KS-KC,MO-KC

Code	Description	Number	Expires
KS-KC	Kansas Department of Health and Environment-KC	E-10110	04/30/2020
KS-NT	Kansas Department of Health and Environment (NELAP)	E-10287	10/31/2020
MO-KC	Missouri Department of Natural Resources	140	04/30/2020
SIA1X	Iowa Department of Natural Resources	95	02/01/2021

End of Report



Keystone Laboratories, Inc.

Carolyn Jackson
Project Manager



PAGE: 1 of 1

BILLY TO:

Ernst Zoller

15 SEPTEMBER 2005

© 2000 Blackwell Science Ltd *Journal of Internal Medicine* 247: 101–107

FAX:

Wk Order #:	1291040
-------------	---------

Rush:

00

Sample #

#

#

Remarks:

11 and 12

12

Time: 17:16

Time: 17:16