

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20191809  
Address: 851 NE WOODS CHAPEL RD, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Hood/Duct Inspection</b>	Khanh Nguyen	Partial	Tuesday, December 17, 2019

Partial Correction:

1	Misc	-DUCT INSPECTION-OK -1ST LAYER OF FIRE-WRAP IN PROGRESS. FIRE-WRAP NEEDS TO GO ALL THE WAY TO THE FAN BASE
---	------	---

**Comments:**